# Electrothermal actuator for zone valves and terminal units

## 

MODEL	POWER SUPPLY	CONTROL		
MVX22R	110-230Vac			
MVX42R	24Vac/Vcc	ON/OFF		
MVX52	24Vac	Proportional 0-10V		

### **APPLICATION AND USE**

MVX electrothermal actuators can be used with Micra® and Micra® Kvs 4-6 valves (DBL199e and DBL293e).

#### **OPERATION**

The actuator-valve assembly is easily made thanks to its threaded ring nut, which allows a comfortable cable positioning. All models are provided with a yellow stroke indicator (see below). The actuators are available in the ON-OFF (230V and 24V) and in modulating (24V) with 0-10Vcc signal versions.

#### **OPTIONS**

PS107 actuator with M28x1,5 modified ring nut. For ordering add suffix PS107 to stardard codes.

#### **TECHNICAL CHARACTERISTICS**

Power supply:

Frequency: Power cable:

Protection degree: Temperature: - operation:

- storage: Force: Stroke:


Material:

24Vac (only for MVX52) 50/60Hz 2m bipolar (0,35mm<sup>2</sup>) 2m triple-pole (0,35mm<sup>2</sup>) for MVX52 IP44 (vertical mounting) 2T50°C -10T60°C 140N 4 mm (MVX22R/42R) 2,5 mm (MVX52) Technopolymer fire-resistant case (class V0)

110 - 230Vac / 24Vac-Vcc

Consumption	MVX22R 230V	MVX22R 110V	MVX42R 24V	MVX52 24V
Starting	50VA	12VA	4VA	5VA
Operation	1.8VA	1.8VA	1.8VA	1.8VA

#### Starting Time:




Actuator timing details (approx.) in seconds								
Actuator	Voltage	Valve opening		Valve closing (after 5' power on)		Valve closing (after 30' power on)		
		Dead zone	Total time	Dead zone	Total time	Dead zone	Total time	
MVX22R	230V	80	230	180	390	150	400	
	110V	100	380	80	330	80	330	
MVX42R-MVX52	24V	150	400	180	390	150	400	

Controlli S.p.A. 16010 Sant'Olcese (GE) Tel. 010 73 06 1 Fax. 010 73 06 870/871 www.controlli.eu











- B = brown (24Vac 50/60Hz)
- G = green (control signal 0-10Vcc)
- W = white (common)


#### **SAFETY PERSCRIPTIONS**

#### 230V products

- Install on the power supply line a screening device to avoid short circuits (fuse or magneto-thermic) according to the reference stadards.
- 2. In case of actuator removing from skilled staff, be sure that the power supply is disconnected.







The performances stated in this sheet can be modified without any prior notice

